

(中)

標稱 截面積	芯線數	導體		絕緣 厚度	被覆 厚度	完成 外徑 (約)	導體電阻 (20°C)	試驗電壓	絕緣電阻 (20°C)	
		組成 線數/單線徑	外徑						PE	PVC
									MΩ-km	
mm	C	No./mm	mm	mm	mm	mm	Ω/km	kv/1min	MΩ-km	
8	2	7/22/0.26	3.9	1.2	1.5	16.0	2.36	2	2000	50
	3	7/22/0.26	3.9	1.2	1.5	17.0	2.36	2	2000	50
	4	7/22/0.26	3.9	1.2	1.5	18.5	2.36	2	2000	50
	5	7/22/0.26	3.9	1.2	1.5	20.5	2.36	2	2000	50
	6	7/22/0.26	3.9	1.2	1.5	22.5	2.36	2	2000	50
	7	7/22/0.26	3.9	1.2	1.5	22.5	2.36	2	2000	50
	8	7/22/0.26	3.9	1.2	1.6	24.5	2.36	2	2000	50
	10	7/22/0.26	3.9	1.2	1.8	29.5	2.36	2	2000	50
	12	7/22/0.26	3.9	1.2	1.8	30.5	2.36	2	2000	50

(英)

Nominal Cross Sectional Area	Core	Conductor		Insulation thickness (average)	Oversheath Thickness (average)	Overall Diameter (approx.)	Max. Conductor Resistance (20°C)	A.C. Voltage Test	Min. Insulation Resistance (20°C)	
		Composi- tion*	Dia. approx.						PE	PVC
									MΩ-km	
mm	C	No./mm	mm	mm	mm	mm	Ω/km	kv/1min	MΩ-km	
8	2	7/22/0.26	3.9	1.2	1.5	16.0	2.36	2	2000	50
	3	7/22/0.26	3.9	1.2	1.5	17.0	2.36	2	2000	50
	4	7/22/0.26	3.9	1.2	1.5	18.5	2.36	2	2000	50
	5	7/22/0.26	3.9	1.2	1.5	20.5	2.36	2	2000	50
	6	7/22/0.26	3.9	1.2	1.5	22.5	2.36	2	2000	50
	7	7/22/0.26	3.9	1.2	1.5	22.5	2.36	2	2000	50
	8	7/22/0.26	3.9	1.2	1.6	24.5	2.36	2	2000	50
	10	7/22/0.26	3.9	1.2	1.8	29.5	2.36	2	2000	50
	12	7/22/0.26	3.9	1.2	1.8	30.5	2.36	2	2000	50